

主要设备参数表:					
REF 编号	NAME 名称	BRAND 品牌	TYPE 型号	DESCRIPTION 参数规格	QTY 数量
1	P5滑道供水泵	NIOSAI	NSW250-315/307	375m ³ /h, 28m, 55kW	1台
2	P6滑道供水泵	NIOSAI	NSW250-315/307	375m ³ /h, 28m, 55kW	1台
3	P7滑道供水泵	NIOSAI	NSW150-315/321	250m ³ /h, 27m, 30kW	1台
4	P8滑道供水泵	NIOSAI	NSW150-315/321	250m ³ /h, 25m, 30kW	1台
5	P9滑道供水泵	NIOSAI	NSW150-250/255	250m ³ /h, 15m, 15kW	1台
6	P10滑道供水泵	NIOSAI	NSW250-250/245	375m ³ /h, 14m, 37kW	1台

REV	DESCRIPTION	DATE	BY

GENERAL NOTES:

LEGEND 图例

- PUMP
水泵
- STRAINER
茶隔过滤器
- AUTOMATIC CONTROL VALVE
电动阀门
- GATE VALVE
闸阀
- DRVZ
静音式止回阀
- FLOW METERS
流量计
- FM
便携式流量计
- KXT
橡胶软管接头
- SWAGE NIPPLE
大小头
- DRAIN POINT
排水点
- TEMPERATURE GAUGE
温度计
- PRESSURE GAUGE
压力表

施工图纸

保安水利工程有限公司
P & A ENGINEERING LIMITED
香港九龍
九龍彌敦道中環大廈
商場廣場6字樓8室
電話: (852) 2521 5100
傳真: (852) 27958871
Website: www.pandaeengineering.com

Pin. 5, 6/F, Corporation Square,
8 Lam Uk St., Kowloon Bay,
Kowloon, Hong Kong (852) 27958871
Fax: (852) 2521 5100

PROJECT 项目名称:

辽宁省铁岭市皇悦南岸•综合商业区
(一期) 水上乐园

TITLE 项目内容:

WP2滑道供水系统图

THIS PRINT ITS COPYRIGHT ARE THE
PROPERTY OF P & A ENGINEERING LIMITED AND
SHALL REMAIN SO UNDER ALL CIRCUMSTANCES

SCALE 比例 N.T.S(A1)

CHECKED BY 校核

APPROVED BY 审批

STATUS OF DRAWING	DRAWING NO. 图号	REV. 修改
ISSUED FOR CONSTRUCTION	PA-WP2-01	A

WP2滑道供水系统流程图

